



Cleanroom[®] Suitable Materials

Rockwool B.V., Rockfon
Report No. RO 1212-628

Medicare Block
Chemical Resistance: excellent

Ceilings & Walls

Qualification Certificate

We hereby certify that the material stated above, provided by

Rockwool B.V., Rockfon
Roermond, The Netherlands

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number RO 1212-628.

The chemical resistance tests on the Medicare Block are performed in accordance with ISO 2812-4. Therefore, the damages according to ISO 4628-1 and VDI 2083-17 are transferred in following classification:

Chemicals	Chemical Resistance	Chemicals	Chemical Resistance
Formalin 37 %	excellent	Phosphoric acid 30 %	excellent
Ammoniac 25 %	excellent	Hydrochloric acid 5 %	excellent
Isopropanol 100 %	excellent	Hydrogen peroxide 30 %	excellent
Sulphuric acid 5 %	excellent	Sodium hydroxide 5 %	excellent
Peracetic acid 15 %	excellent	Sodium hypochlorite 15 %	excellent

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, March 8, 2013

i. A. 
Project manager

DUPLICATE

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified on www.tested-device.com.

For more CSM information, please visit www.ipa-csm.com.